

KARL F. DEAN  
MAYOR



## **METROPOLITAN GOVERNMENT OF NASHVILLE AND DAVIDSON COUNTY**

STEPHEN D. HALFORD  
DIRECTOR-CHIEF

DANNY W. HUNT  
FIRE MARSHAL

NASHVILLE FIRE DEPARTMENT  
FIRE MARSHAL'S OFFICE  
63 HERMITAGE AVE.  
P.O. BOX 196332  
NASHVILLE, TN 37219-16332  
(615) 862-5230

**December 30, 2009**

**TO: Multi-Family Dwelling Complex Managers**  
**FROM: The Fire Marshal's Office**  
**Nashville Fire Department**

**RE: Grills on Balconies**

The Metropolitan Council has adopted the "2006 edition of The International Fire Code" with some local amendments as Davidson County's fire code. There are some changes in the previous law concerning grills on combustible balconies or within 10 feet of combustible construction. The new fire code states that open flame cooking devices are not allowed on combustible balconies or within 10 feet of combustible construction unless the building and the deck is protected with an approved automatic fire sprinkler system.

The second section of the code states that even when grills are allowed because of construction or fire sprinklers LP gas fueled grills can't have storage cylinders with a water capacity larger than 2.5 pounds.

### **IFC**

#### **308.3.1 Open-flame cooking devices.**

Charcoal burners and other open-flame cooking devices shall not be operated on combustible balconies or within 10 feet (3048 mm) of combustible construction.

Exceptions:

1. One- and two-family dwellings.
2. Where buildings, balconies and decks are protected by an automatic sprinkler system.

#### **308.3.1.1 Liquefied-petroleum-gas-fueled cooking devices.**

LP-gas burners having an LP-gas container with a water capacity greater than 2.5 pounds [nominal 1 pound (0.454 kg) LP-gas capacity] shall not be located on combustible balconies or within 10 feet (3048 mm) of combustible construction.

Exception: One- and two-family dwellings.

**Good fire prevention practices should always be used when operating a grill. Always have a way of extinguishing the fire and never leave the grill unattended. Remember that your actions may have an effect on several. Always think fire safety.**